

RESULTS LOG SHEET



Contact: Liam Ball
Mobile: 07949 274378

Engineer: James Caraig
Test Date: 24th June 2025
Equipment used: Seaward Apollo 600+
Test count: 20

Asset ID	Description	Earth Continuity Value (ohm)	IR Value (Mohm)	Visual Result	Overall Result
JC7001	Power Supply Unit	N/A	> 19.99	PASSED	PASSED
JC7002	Power Supply Unit	N/A	> 19.99	PASSED	PASSED
JC7003	Power Supply Unit	N/A	> 19.99	PASSED	PASSED
JC7004	Power Supply Unit	N/A	> 19.99	PASSED	PASSED
JC7005	Extension	0.14	> 19.99	PASSED	PASSED
JC7006	Extension	0.17	> 19.99	PASSED	PASSED
JC7007	Extension	0.13	> 19.99	PASSED	PASSED
JC7008	Extension	0.12	> 19.99	PASSED	PASSED
JC7009	Extension	0.11	> 19.99	PASSED	PASSED
JC7010	Appliance Lead	0.04	> 19.99	PASSED	PASSED
JC7011	Appliance Lead	0.05	> 19.99	PASSED	PASSED
JC7012	Appliance Lead	0.08	> 19.99	PASSED	PASSED
JC7013	Extension	0.13	> 19.99	PASSED	PASSED
JC7014	Extension	0.09	> 19.99	PASSED	PASSED
JC7015	Power Supply Unit	N/A	> 19.99	PASSED	PASSED
JC7016	Power Supply Unit	N/A	> 19.99	PASSED	PASSED
JC7017	Extension	0.1	> 19.99	PASSED	PASSED
JC7018	Extension	0.1	> 19.99	PASSED	PASSED
JC7019	Speaker	0.06	> 19.99	PASSED	PASSED
JC7020	Speaker	0.06	> 19.99	PASSED	PASSED